

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:39 pm

**PWS ID:** UTAH22078      **Name:** CAMP PINECLIFF (METHODIST)

**Legal Contact:** CAMP PINECLIFF      **Rating:** Approved  
VERN ROSENSTIEL      **Rating Date:** 04/09/1996

**Address:** 12885 SO FORT STREET      **Activity Status:** Active  
DRAPER, UT 84020

**Phone Number:** 435-336-4504

**City Served (Area):**

**County:** SUMMIT COUNTY

**System Type:** Non-community      **Last Inv Update:** 05/28/2010      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 08/31/2009      **Total Dsgn Cap:**  
**Population:** 75      **Surveyor:** BRAD K HOLDAWAY      **Total Emerg Cap:**  
**Oper Period:** 5/1 to 9/30

**Gal/Day   Gal/Min**

### Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	ROSENSTIEL, VERN		801-572-0417		

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	4
			4 Total Svc Connections

### Storage

**Total Storage:** 3,700 GAL      **Number of Units:** 1      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	3,700 GAL	Concrete		A	

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	PINECLIFF CHLORINATOR		A	

### Distribution System

Pump Type	Total Dyn Head ft H2O   P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	PINE CLIFF WELL	Active	WL			10 GPM	Yes	GW	Permanent	5/1 to 9/30	

\*Reports measured flow for wells, approved design capacity for all other sources.